

HYDRAZINE TEST RESULT ppm						
Boiler Pressure	Control Range	0-0.05ppm	0.05-0.10	0.10-0-50	0.50-1.00	1.00-1.50
<18 to 31 bar	0.1-1.0ppm	Increase dose 25%	Increase dose 25%	Satisfactory Maintain dose	Satisfactory Maintain dose	Decrease dose 25%
31 to 42 bar	0.1-0.5ppm	Increase dose 25%	Increase dose 25%	Satisfactory Maintain dose	Decrease dose 25%	Decrease dose 25%

Recommended Control Limits in ppm. These are typical values. Follow boiler manufacturers guidelines where required.

Wet lay-up

When wet lay-up of the boiler is required then a minimum dosage of 1.25 litres/tonne of boiler water is required.

Sampling and testing

A representative sample of boiler water should be drawn for analysis daily. The sample should always be taken from the same point after blowdown, cooled and tested immediately. Follow the WSS Test Kit instructions and log the results in Waterproof. The results should be sent to WSS as stated in the Waterproof instructions. It is important that regular testing is carried out to ensure levels of treatment are correct.

Related products

Accessories

Test Kits for Hydrazine, P Alkalinity, Chloride and pH.

555490
SPECTRAPAK 312
739490
SPECTRAPAK 315

Is frequently bought together with

680843
COOLTREAT AL 25 LTR
571364
VAPTREAT 25LTR
571356
ROCOR NB LIQUID 25 LTR
735977
MAR-71 BIOCID 3X5L NOT IN USA&CAN
638676
EVAPORATOR DEFOAMER 4X5 LTR
698720
AUTOTREAT - 25 LTR
777710
NALFLEET 2000 25 LTR

This page is printed from

<https://www.wilhelmsen.com/zh-hans/product-catalogue/products/marine-chemicals/water-treatment-chemicals/boiler-water-treatment/oxygen-control-25-ltr>